

## Paul Michaud

---

**From:** Gary Griffith <gary.griffith@phoenix.gov>  
**Sent:** Thursday, July 28, 2016 3:10 PM  
**To:** Fred Fleet  
**Cc:** Paul Michaud  
**Subject:** RE: IRONWOOD DRIVE LOT SPLIT

It appears that the pressure should be around 77 psi and flow rate around 1500 gpm. Actual measurements should be taken to verify these numbers.

---

**From:** Fred Fleet [[mailto:fef\\_@cvlci.com](mailto:fef_@cvlci.com)]  
**Sent:** Thursday, July 28, 2016 3:05 PM  
**To:** Gary Griffith <gary.griffith@phoenix.gov>  
**Cc:** Paul Michaud <[pmichaud@paradisevalleyaz.gov](mailto:pmichaud@paradisevalleyaz.gov)>  
**Subject:** IRONWOOD DRIVE LOT SPLIT

GARY-

WHAT IS THE APPROXIMATE FLOW AND PRESSURE AT THE CITY OF PHOENIX FIRE HYDRANT #408 AT THE INTERSECTION OF IRONWOOD DRIVE AND NORTHER AVENUE IN THE TOWN OF PARADISE VALLEY AS PER C.O.P. ¼ SECTION MAP #24-42?

**Fred E. Fleet, P.E., F. ASCE**  
**Senior Project Manager**

---

Main: 602-264-6831 direct: 602.285.4768 fax: 602.264.0928 cell: 602-228-3802

**COE & VAN LOO CONSULTANTS, INC.**  
4550 N. 12th Street • Phoenix, Arizona • 85014