TOWN OF PARADISE VALLEY

5112 N Casa Blanca Dr Lot Split (LS-16-3) & 5102 N Casa Blanca Dr Lot Split (LS-16-4)

Town Council June 9, 2016



LOT SPLIT REQUEST

- Two separate actions
- 5112 & 5102 N Casa Blanca Dr Subdivide 2.26 acre parcels into two lots each:
 - Camelback Lands 3 5112 N Casa Blanca Dr LS
 - Camelback Lands 4 5102 N Casa Blanca Dr LS







PC DISCUSSION

- Commission discussed lot splits at May 3rd work study session and May 17th public meeting
- Commission made recommendation of approval of each lot split subject to stipulations




CAMELBACK LANDS 3 & 4 LOT SPLIT

- ARS 6.2, Section 9-463 defines Lot Split as:
 - The division of improved or unimproved land whose area is two and one-half acres or less into two or three tracts or parcels of land for the purpose of sale or lease
- Existing Lot Size: 2.26 acres each
- Proposed Lot Sizes: 1.13 acres (Lot 1) each
 - 1.13 acres (Lot 2) each



5112 N Casa Blanca Dr - Existing Structures to be Demolished






5102 N Casa Blanca Dr - Vacant Lot with Construction Materials and Storage Container to be Removed
















CAMELBACK LANDS 3 & 4 LOT SPLIT

- Lot Configuration:
 - Proposed lots meet R-43 area requirements:
 - Size (1 net acre +)
 - Width (165' wide)
 - Access (public roadway)
 - Setbacks (40' front/rear and 20' sides)



CAMELBACK LANDS 3 & 4 LOT SPLIT (CONT.)

- Drainage:
 - On site retention and grading at building permit
- Casa Blanca Dr:
 - No ROW dedication required:
 - 60' wide ROW (50' wide required)
 - Roadway improvements prior to CofO



CAMELBACK LANDS 3 & 4 LOT SPLIT (CONT.)

- Fire Protection:
 - Access via public roadway
 - o Installation of fire hydrant required
 - o New homes will have fire sprinklers
 - o Fire flow rate slightly below minimum:
 - 1,500 gpm needed
 - 1,353 gpm for this area



RECOMMENDATION - APPROVAL

- Both lot splits meet Town Development Standards
- Fire flow is substantially compliant and addressed via stipulation
- Recommended approval subject to stipulations




STIPULATIONS

- Lot splits must be in accordance with submitted plans and docs
- 2. Prior to the issuance of a Certificate of Occupancy for a new single-family residence, the fire sprinkler system shall demonstrate compliance to the National Fire Protection Association standard 13D or the current equivalent code requirement



STIPULATIONS (CONT.)

- 3. Roadway improvements shall be installed prior to issuance of Certificate of Occupancy for new single family residence
- 4. 5112 N Casa Blanca Demolition permit must be obtained and existing structures removed prior to recordation of plat
- 5. 5102 N Casa Blanca Construction materials and storage container must be removed prior to recordation of the plat





QUESTION?