

# Water Flow Test Record


Input information in non-shaded areas only.

## Test Data Information

Test Hydrant Number		Date	29-Apr-16
Location		Static Pressure (psig)	76
NW Corner of Jack Rabbit and Casa Blanca Rd, Paradise Valley		Residual Pressure (psig)	70
Flow Hydrant #1		Outlet Size (inches)	2.5
Flow Hydrant #2		Coefficient	0.9
Flow Hydrant #3		Pitot Pressure	65
Flow Hydrant #4		Test Flow (gpm)	1353
Flow Hydrant #5		Flow (gpm) available @ 20 psi	4519
Flow Hydrant #6		Flow (gpm) available @ 10 psi	4938
			A
			#VALUE!
			0
			0

Column heading color correlates to line color on the chart

### Water Flow Test Chart



(For multiple test information printed on one chart, color printer required)