

Paul Michaud

From: Gary Griffith <gary.griffith@phoenix.gov>
Sent: Thursday, July 28, 2016 3:10 PM
To: Fred Fleet
Cc: Paul Michaud
Subject: RE: IRONWOOD DRIVE LOT SPLIT

It appears that the pressure should be around 77 psi and flow rate around 1500 gpm. Actual measurements should be taken to verify these numbers.

From: Fred Fleet [mailto:fef_@cvlci.com]
Sent: Thursday, July 28, 2016 3:05 PM
To: Gary Griffith <gary.griffith@phoenix.gov>
Cc: Paul Michaud <pmichaud@paradisevalleyaz.gov>
Subject: IRONWOOD DRIVE LOT SPLIT

GARY-

WHAT IS THE APPROXIMATE FLOW AND PRESSURE AT THE CITY OF PHOENIX FIRE HYDRANT #408 AT THE INTERSECTION OF IRONWOOD DRIVE AND NORTHER AVENUE IN THE TOWN OF PARADISE VALLEY AS PER C.O.P. ¼ SECTION MAP #24-42?

Fred E. Fleet, P.E., F. ASCE
Senior Project Manager

Main: 602-264-6831 direct: 602.285.4768 fax: 602.264.0928 cell: 602-228-3802

COE & VAN LOO CONSULTANTS, INC.
4550 N. 12th Street • Phoenix, Arizona • 85014