

Hydrant Flow Test Report

Test Date 10/18/2018

Test Time 0800 Hrs.

Location

7525 N. Ironwood Drive Paradise Valley, AZ
85253

Tested by

Sunstate Fire Protection

Notes

Witnessed by EPCOR

Read Hydrant

68 psi static pressure

62 psi residual pressure

2 ft hydrant elevation

Flow Hydrant(s)

Outlet	Elev	Size	C	Pitot Pressure	Flow
#1	2	2.5	.9	40	1062 gpm

Flow Graph

