



## Legislation Details (With Text)

**File #:** 21-147      **Version:** 1      **Name:**

**Type:** Hillside      **Status:** Agenda Ready

**File created:** 4/8/2021      **In control:** Hillside Building Committee

**On agenda:** 4/14/2021      **Final action:** 4/14/2021

**Title:** Concept Review for a new single family residence at 5455 E Desert Jewel Drive (APN 169-06-068).

**Sponsors:**

**Indexes:**

**Code sections:**

**Attachments:** 1. Hillside Map.pdf, 2. Vicinity Map.pdf, 3. Aerial.pdf, 4. Application.pdf, 5. Notification Materials.pdf, 6. Narrative.pdf, 7. Report.pdf, 8. Plans.pdf, 9. Video.mp4

| Date | Ver. | Action By | Action | Result |
|------|------|-----------|--------|--------|
|------|------|-----------|--------|--------|

4/14/2021      1      Hillside Building Committee

**To:** Hillside Building Committee

**From:** Hugo Vasquez; Hillside Development Administrator

**Date:** April 14<sup>th</sup>, 2021

**Subject:** Concept Review for a new single family residence at 5455 E Desert Jewel Drive (APN 169-06-068).

**Narrative:** The proposed project shall construct a new single family residence. The new project has an application date of December 23<sup>rd</sup>, 2020 and will be reviewed under the 2018 Hillside Development Regulations.

| Lot Data |                               |                                    |
|----------|-------------------------------|------------------------------------|
| 1.       | Area of Lot                   | 1.128 ac or 49,155 ft <sup>2</sup> |
| 2.       | Area Under Roof               | 11,257 ft <sup>2</sup>             |
| 3.       | Floor Area Ratio              | 22.90%                             |
| 4.       | Building Site Slope           | 16.75%                             |
| 5.       | Allowable Disturbed Area      | 13,799 ft <sup>2</sup> (28.07%)    |
| 6.       | Existing Gross Disturbed Area | 28,956 ft <sup>2</sup> (58.91%)    |
| 7.       | Proposed Net Disturbed Area   | 13,345 ft <sup>2</sup> (27.15%)    |
| 8.       | Maximum Building Height       | To Be Determined                   |
| 9.       | Overall Height                | To Be Determined                   |
| 10.      | Volume of Cut/Fill            | 3,136 yd <sup>3</sup>              |
| 11.      | Hillside Assurance            | \$105,917                          |

### Background

The property contains an existing single family residence constructed in 1990.

### **Single Family Residence**

The new project shall demolish the existing residence and construct a new single family residence with an approximate total of 7,800 ft<sup>2</sup> of livable area.

### **Guesthouse**

An attached guesthouse is proposed.

### **Driveway**

A new driveway has been proposed entering from E Desert Jewel Drive.

### **Pool**

A pool is proposed southwest of the main residence. The applicant should consider a method of draining the pool into proposed sewer cleanouts on the property.

### **Materials**

No proposed material details have been provided at this point.

### **Landscaping**

No proposed landscaping details have been provided at this point.

### **Land Disturbance**

A gross disturbed area of 58.91% (28,956 ft<sup>2</sup>) currently exists on the lot and the building pad slope of 16.75% allows a disturbance of 28.07% (13,799 ft<sup>2</sup>) the lot. The applicant has proposed a net disturbed area of approximately 27.15% (13,345 ft<sup>2</sup>), which is less than the allowable disturbance.

### **Grading and Drainage**

A preliminary grading and drainage plan has been provided. The proposed construction of the property shall be required properly retain the “pre vs post” storm water volumes for the 100-year, 2-hour rainfall event. A large retention basin is proposed for the site development.

### **Sewer**

A public sewer connection is currently available on the property.

### **Hillside Safety Improvement Plan**

The Applicant has submitted a Hillside Safety Improvement Plan in accordance with the Hillside Safety Improvement Measures and Process Manual per Section 5-10-9 of the Town Code.

The Hillside Building Committee Formal Review Meeting shall not be scheduled until the Town Engineer and/or Technical Advisory Board are satisfied with the Applicant's Registered Professional Engineer sealed reports comprising the Safety Improvement Plan and the Formal Hillside Plans. The Safety Improvement Plan shall remain the responsibility of the Applicant and have the seal of the Applicant's Engineer who shall be liable for any failures.

### **Conceptual Plan Review**

The purpose of the Conceptual Plan Review Meeting is to discuss, review, and give suggestions and guidance to the applicant. A detailed set of plans will be submitted for formal review in accordance with Section 2206.I. The following criteria are sections of the Hillside Building Code that govern the conceptual review:

- **Section 2205.III - Concept Plan Review Meeting:**

The Applicant, along with their architect and engineer shall submit a completed application and the required fees, to the Town Engineer, at the time they request a concept plan review meeting (pre-hillside meeting) with the Hillside Building Committee. The purpose of this meeting is to discuss, review, and give suggestions and guidance to the Applicant regarding the proposed development including: the location of the building pad and accessory uses; how these relate to Significant Natural Features; the preservation of existing vegetation; grading concepts and their adaptation to the natural hillside topography; and how the requirements pursuant to these hillside regulations and purpose statement will guide the proposed Development.

- Section 2206.II - Concept Plan Review Meeting.

The applicant shall submit the following:

- A. Seven (7) copies of a preliminary site plan that includes, but is not limited to, the building footprint, driveway, swimming pool, and accessory use locations along with topographic information for the lot.
- B. A 3-dimensional representation of the general massing of all proposed structures (e.g. a mass model, a 3-D rendering or a computer-generated model in relation to topography - not a detail model).
- C. A recent aerial photo of the site (less than 1 year old), with topography, lot lines, and the building footprint superimposed on it, and identification of significant natural features as well as adjacent lots and structures within 100 feet of the perimeter of the subject property (min. 24"X 36"), and the location of the driveway access in relation to the nearest roadway.
- D. Preliminary calculations on land disturbance and cut and fill methods.